

## SAMUEL HEATH Declaration of Performance



| 1. Product name:   | Perko Powermatic   |
|--|--|
| 2. Product serial number:  | R100   |
| 3. Legislation with which product complies:  | Construction Products<br>Regulations   |
| 4. Intended use or uses of<br>the construction product, in<br>accordance with the applicable<br>technical specification, as foreseen<br>by the manufacturer: | For use on fire and smoke compartmentation doors   |
| 5. Declaration:  | The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011 as it has effect in the United Kingdom in respect of Great Britain, under the sole responsibility of the manufacturer identified above. |
| 6. Company name & address:   | Samuel Heath and Sons PLC,<br>Leopold Street,<br>Birmingham, B12 OUJ   |
| 7. Approved body:  | EOR - 1121 performed the type testing and issued test reports.   |
| 8. Standard(s) against which product assessed:   | BS EN 1154:1996:A1:2002  |
| 9. System or systems of assessment<br>and verification of constancy of<br>performance of the construction<br>product as set out in CPR, Annex V:             | System 1   |

| 10. De   | clared Performance         |                        |                                    |
|----------|----------------------------|------------------------|------------------------------------|
|          | Essential characteristics  | Performance            | Harmonised technical specification |
|          | Self closing               |                        |                                    |
| 5.2.1    | General                    |                        |                                    |
| 5.2.2    | Durability                 | 500,000 Test<br>Cycles | BS1154:1996:A1:2002                |
| 5.2.3    | Closing Movement           | Pass Size 3            | BS1154:1996:A1:2002                |
| 5.2.4    | Opening Movement           | Pass Size 1            | BS1154:1996:A1:2002                |
| 5.2.5    | Efficiency                 | 55% min                | BS1154:1996:A1:2002                |
| 5.2.6    | Closing time               | Pass                   | BS1154:1996:A1:2002                |
| 5.2.7    | Angles of Operation        | Grade 3, 105°          | BS1154:1996:A1:2002                |
| 5.2.8    | Overload Performance       | Pass                   | BS1154:1996:A1:2002                |
| 5.2.9    | Temperature Dependence     | -15°C to +40°C         | BS1154:1996:A1:2002                |
| 5.2.10   | Fluid Leakage              | Pass                   | BS1154:1996:A1:2002                |
| 5.2.11   | Damage                     | Pass                   | BS1154:1996:A1:2002                |
| 5.2.18   | Fire I smoke doors         | Pass                   |                                    |
|          | Durability of Self Closing |                        |                                    |
| 5.2.2    | Durability                 | 500,000 Test<br>Cycles | BS1154:1996:A1:2002                |
| 5.2.17.1 | Corrosion                  | Grade 3 (96 hours)     |                                    |
| 5.2.17.2 | Corrosion                  | Pass                   |                                    |
|          | Dangerous Substances       | ŇPĎ                    |                                    |

Signed for and on behalf of the manufacturer by:

**Adam Daniels** 

Samuel Heath & Sons plc

Leopold Street, Birmingham, England B12 OUJ

Sales Office Direct Line: +44 (0)121 766 4200

email: info@samuel-heath.com www.samuel-heath.com Date: 1/1/2021